



April 7, 2021

To: All Prospective Bidders

Reference: **Invitation for Bids for Design, Supply, Installation and Commissioning of a 174 kWp Off-Grid Solar Photovoltaic Micro-Grid System and Electrical Distribution Network in Capoey Mission & 39.5 kWp Off-Grid Solar Photovoltaic Micro-Grid System and Electrical Distribution Network in Capoey Lake Top.**

Dear Sirs,

Subject: Addendum No. 1

Further to the tender for the referenced project, we now issue this Bid Addendum No. 1 to modify the Bidding Documents.

Reference	Original	Amendment as
Technical Specifications		
4.15	Pad Mounted Transformer 150kVA (Mission) / 50kVA (Lake Top), Three Phase Step-up transformer	Pad Mounted Transformer 225kVA (Mission) / 50kVA (Lake Top), Three Phase Step-up transformer
Price Schedule		
Lot 2	150 kVA, 480V-13.8kV, 60Hz Step-up Pad Mounted 3PH Transformer	225 kVA, 480V-13.8kV, 60Hz Step-up Pad Mounted 3PH Transformer

This addendum should be read in conjunction with the Bidding Document.

Should you require any further clarifications, do not hesitate to contact me.

Yours sincerely,

.....
Dr. Mahender Sharma
Chief Executive Officer