

MINUTES OF MEETING

Supply and Delivery of 2,000 (Two thousand) Energy Efficient Street Lights to the Ministry of Public Works, Wright's Lane, Kingston, Georgetown.

Call to Order

A Pre Bid Tender meeting hosted by Guyana Energy Agency was held via Zoom on March 17, 2021 at 10:05 am with bidders.

Introduction

Introduction was given by Shareefa Toolsiram

Administrative Matters

Shareefa Toolsiram give update on the Evaluation and Qualification Criteria and Deadline of Submission of Bid

No questions were asked relating to Administrative Matters

Specifications of Bid

Specifications of Bid was given by engineer Cyril Ohanwusi

Questions

Q: Are all certification required?

A: It doesn't have to be all, the MPW mandatorily requires the UL and RoHS. Any additional certificate is acceptable.

Q: Does the MPW requires a US or European certified product?

A: (US standard) UL certification is a must.

Q: Would IP 65 be accepted?

A: Only IP 66 will be accepted.

Q: How will the IP 66 be tested?

A: The certification process is important, if suspected to be non-compliant, will be taken to laboratory for testing.

Q: Is the Ministry willing to test the samples presented by the bidders?

A: No, only if an agreement from the bidder is included to foot all associated bills incurred.

Q: What measures can be placed to have theft proof lights?

A: Features such as; special screws, antitheft bolts and locking devices.

Q: Is there a bar code that can be used?

A: There is an identifier, "GoG LED" that must be used (screen printed on each lamp, not stickers that can be easily removed)

Q: Is there an advantage if you provide 10 years warranty?

A: No, but we will accept 10 years if we don't have to pay an additional cost.

Q: Is there a specific requirement on the driver quality and mean time between failure?

A: This will be reviewed by the technical team of the MPW and GEA which will be communicated to the bidders accordingly.

Q: What is the minimum volts that can be used.

A: 85-277 volts is acceptable.

Q: Can delivery time be extended to 120 days?

A: It will remain at 90 days.

Closed

Meeting was adjourned at 10:52am